

Contaminate levels based on the United States Environmental Protection Agency's: National Primary Drinking Water Regulations*

| | |
|---|----------------------------------|
| Alachlor | 0.002 |
| Alpha/photon emitters | 15 picocuries per Liter (pCi/L) |
| Antimony | 0.006 |
| Arsenic | 0.010 |
| Asbestos (fibers >10 micrometers) | 7 million fibers per Liter (MFL) |
| Atrazine | 0.003 |
| Barium | 2 |
| Benzene | 0.005 |
| Benzo(a)pyrene (PAHs) | 0.0002 |
| Beryllium | 0.004 |
| Beta photon emitters | 4 millirems per year |
| Bromate | 0.010 |
| Cadmium | 0.005 |
| Carbofuran | 0.04 |
| Carbon tetrachloride | 0.005 |
| Chloramines (as Cl ₂) | MRDL=4.0 ¹ |
| Chlordane | 0.002 |
| Chlorine (as Cl ₂) | MRDL=4.0 ¹ |
| Chlorine dioxide (as ClO ₂) | MRDL=0.8 ¹ |
| Chlorite | 1.0 |
| Chlorobenzene | 0.1 |

| | |
|------------------------------------|------------------|
| Chromium (total) | 0.1 |
| Copper | Action Level=1.3 |
| Cyanide (as free cyanide) | 0.2 |
| 2,4-D | 0.07 |
| Dalapon | 0.2 |
| 1,2-Dibromo-3-chloropropane (DBCP) | 0.0002 |
| o-Dichlorobenzene | 0.6 |
| p-Dichlorobenzene | 0.075 |
| 1,2-Dichloroethane | 0.005 |
| 1,1-Dichloroethylene | 0.007 |
| cis-1,2-Dichloroethylene | 0.07 |
| trans-1,2, Dichloroethylene | 0.1 |
| Dichloromethane | 0.005 |
| 1,2-Dichloropropane | 0.005 |
| Di(2-ethylhexyl) adipate | 0.4 |
| Di(2-ethylhexyl) phthalate | 0.006 |
| Dinoseb | 0.007 |
| Dioxin (2,3,7,8-TCDD) | 0.00000003 |
| Diquat | 0.02 |
| Endothall | 0.1 |
| Endrin | 0.002 |

| | |
|---|--------------------|
| Ethylbenzene | 0.7 |
| Ethylene dibromide | 0.00005 |
| Fluoride | 4.0 |
| Glyphosate | 0.7 |
| Haloacetic acids (HAA5) | 0.060 |
| Heptachlor | 0.0004 |
| Heptachlor epoxide | 0.0002 |
| Hexachlorobenzene | 0.001 |
| Hexachloro-cyclopentadiene | 0.05 |
| Lead | Action Level=0.015 |
| Lindane | 0.0002 |
| Mercury (inorganic) | 0.002 |
| Methoxychlor | 0.04 |
| Nitrate (measured as Nitrogen) | 10 |
| Nitrite (measured as Nitrogen) | 1 |
| Oxamyl (Vydate) | 0.2 |
| Pentachlorophenol | 0.001 |
| Picloram | 0.5 |
| Polychlorinated biphenyls (PCBs) | 0.0005 |
| Radium 226 and Radium 228 (combined) | 5 pCi/L |
| Selenium | 0.05 |
| Simazine | 0.004 |
| Styrene | 0.1 |
| Tetrachloroethylene | 0.005 |
| Thallium | 0.002 |

| | |
|--------------------------------------|-------------|
| Toluene | 1 |
| Total Coliforms | 5.0 percent |
| Total Trihalomethanes (TTHMs) | 0.080 |
| Toxaphene | 0.003 |
| 2,4,5-TP (Silvex) | 0.05 |
| 1,2,4-Trichlorobenzene | 0.07 |
| 1,1,1-Trichloroethane | 0.2 |
| 1,1,2-Trichloroethane | 0.005 |
| Trichloroethylene | 0.005 |
| Uranium | 30µg/L |
| Vinyl chloride | 0.002 |
| Xylenes (total) | 10 |

*To view the complete standard, visit the link below:
[Environmental Protection Agency standard](#)